

DOMESTIC ELECTRICAL INSTALLATION PERIODIC INSPECTION REPORT (FOR A SINGLE DWELLING)

Issued in accordance with *British Standard 7671 – Requirements for Electrical Installations* by an Approved Contractor or Conforming Body enrolled with NICEIC, Warwick House, Houghton Hall Park, Houghton Regis, Dunstable LU5 5ZX.

Original (To the person ordering the work)

<h3 style="background-color: #c00; color: white; padding: 2px;">A DETAILS OF THE CLIENT</h3> <p>Client / Address:</p>	<h3 style="background-color: #c00; color: white; padding: 2px;">B ADDRESS AND DETAILS OF THE INSTALLATION</h3> <p>Address:</p> <p>Estimated age of the electrical installation: <input type="text"/> years</p> <p>Evidence of alterations or additions: <input type="text"/> If yes, estimated age: <input type="text"/> years</p> <p>Date of previous inspection: <input type="text"/> Electrical Installation Certificate number or previous Periodic Inspection Report number: <input type="text"/></p> <p>Records of installation available: <input type="text"/> Records held by: <input type="text"/></p>										
<h3 style="background-color: #c00; color: white; padding: 2px;">C PURPOSE OF THE REPORT</h3> <p>† (see note below)</p> <p>Purpose for which this report is required:</p>	<h3 style="background-color: #c00; color: white; padding: 2px;">D EXTENT OF THE INSTALLATION AND LIMITATIONS OF THE INSPECTION AND TESTING</h3> <p>‡ (see note below)</p> <p>Extent of the electrical installation covered by this report:</p> <p>Agreed limitations, if any, on the inspection and testing:</p>										
<h3 style="background-color: #c00; color: white; padding: 2px;">E PARTICULARS OF THE APPROVED CONTRACTOR</h3> <p>Trading Title:</p> <p>Address:</p> <p style="text-align: right;">Postcode</p> <p>NICEIC Enrolment No (Essential information) <input type="text"/></p> <p>Branch No: (if applicable) <input type="text"/></p>	<h3 style="background-color: #c00; color: white; padding: 2px;">F DECLARATION</h3> <p>I/We, being the person(s) responsible for the inspection and testing of the electrical installation (as indicated by my/our signatures below), particulars of which are described above (see B), having exercised reasonable skill and care when carrying out the inspection and testing, hereby declare that the information in this report, including the observations (see G) and the attached schedules (see K and L), provides an accurate assessment of the condition of the electrical installation taking into account the stated extent of the installation and the limitations of the inspection and testing (see D).</p> <p>I/We further declare that in my/our judgement, the said installation was overall in <input type="text"/> condition (see H) at the time the inspection was carried out, and that it should be further inspected as recommended (see I).</p> <p style="text-align: center;">* (Insert 'a satisfactory' or 'an unsatisfactory', as appropriate)</p> <table style="width: 100%;"> <tr> <td style="width: 50%;"> INSPECTION, TESTING AND ASSESSMENT BY: </td> <td style="width: 50%;"> REPORT REVIEWED AND CONFIRMED BY: *See note below </td> </tr> <tr> <td>Signature: <input type="text"/></td> <td>Signature: <input type="text"/></td> </tr> <tr> <td>Name: (CAPITALS) <input type="text"/></td> <td>Name: (CAPITALS) <input type="text"/></td> </tr> <tr> <td>Position: <input type="text"/></td> <td style="text-align: center;">(Registered Qualified Supervisor for the Approved Contractor at E)</td> </tr> <tr> <td>Date: <input type="text"/></td> <td>Date: <input type="text"/></td> </tr> </table>	INSPECTION, TESTING AND ASSESSMENT BY:	REPORT REVIEWED AND CONFIRMED BY: *See note below	Signature: <input type="text"/>	Signature: <input type="text"/>	Name: (CAPITALS) <input type="text"/>	Name: (CAPITALS) <input type="text"/>	Position: <input type="text"/>	(Registered Qualified Supervisor for the Approved Contractor at E)	Date: <input type="text"/>	Date: <input type="text"/>
INSPECTION, TESTING AND ASSESSMENT BY:	REPORT REVIEWED AND CONFIRMED BY: *See note below										
Signature: <input type="text"/>	Signature: <input type="text"/>										
Name: (CAPITALS) <input type="text"/>	Name: (CAPITALS) <input type="text"/>										
Position: <input type="text"/>	(Registered Qualified Supervisor for the Approved Contractor at E)										
Date: <input type="text"/>	Date: <input type="text"/>										

† This Domestic Periodic Inspection Report must be used only for reporting on the condition of an existing installation.

‡ The inspection and testing have been carried out in accordance with BS 7671, as amended. Cables concealed within trunking and conduits, or cables and conduits concealed under floors, in inaccessible roof spaces and generally within the fabric of the building or underground, have not been visually inspected.

* This Domestic Periodic Inspection Report should be reviewed and confirmed by the registered Qualified Supervisor of the Approved Contractor responsible for issuing it.

Please see the 'Notes for Recipients' on the reverse of this page.

NOTES FOR RECIPIENT

TRACEABLE
SERIAL NUMBER

THIS REPORT IS AN IMPORTANT AND VALUABLE DOCUMENT WHICH SHOULD BE RETAINED FOR FUTURE REFERENCE

The purpose of periodic inspection is to determine, so far as is reasonably practicable, whether an electrical installation is in a satisfactory condition for continued service. This report provides an assessment of the condition of the electrical installation identified overleaf at the time it was inspected, taking into account the stated extent of the installation and the limitations of the inspection and testing.

The report has been issued in accordance with the national standard for the safety of electrical installations, British Standard 7671 (as amended) - Requirements for Electrical Installations (formerly known as the IEE Wiring Regulations).

If you were the person ordering the work, but not the user of the installation, you should pass this report, or a full copy of it including these notes, the schedules and additional pages (if any), immediately to the user.

The 'Original' report form should be retained in a safe place and shown to any person inspecting or undertaking further work on the electrical installation in the future. If you later vacate the property, this report will provide the new user with an assessment of the condition of the electrical installation at the time the periodic inspection was carried out.

Where the installation incorporates a residual current device (RCD), there should be a notice at or near the main switchboard or consumer unit stating that the device should be tested at quarterly intervals. For safety reasons, it is important that you carry out the test regularly.

Also for safety reasons, the electrical installation will need to be re-inspected at appropriate intervals by a competent person. The recommended maximum time interval to the next inspection is stated on page 2 in Section I (Next Inspection). NICEIC* recommends that you engage the services of an Approved Contractor for this purpose. There should be a notice at or near the main switchboard or consumer unit indicating when the next inspection of the installation is due.

Only an NICEIC Approved Contractor or Conforming Body is authorised to issue this NICEIC Domestic Electrical Installation Periodic Inspection Report form.

The report consists of at least three numbered pages. Additional numbered pages may have been provided to permit further relevant information concerning the installation to be recorded. The report is invalid if any of the identified pages are missing. The report has a printed seven-digit serial number, which is traceable to the Approved Contractor to which it was supplied by NICEIC.

This report is intended to be issued only for the purpose of reporting on the condition of an existing electrical installation. The report should identify, so far as is reasonably practicable and having regard to the extent and limitations recorded in Section D, any damage, deterioration, defects, dangerous conditions and any non-compliances with the requirements of the national standard for the safety of electrical installations which may give rise to danger. It should be noted that the greater the limitations applying to a report, the less its value.

This report should not have been issued to certify that a new electrical installation complies with the requirements of the national safety standard. A 'Domestic Electrical Installation Certificate' or 'Electrical Installation Certificate' should be issued for the certification of a new installation.

You should have received the report marked 'Original' and the Approved Contractor should have retained the report marked 'Duplicate'.

Section D addresses the extent and limitations of the report by providing boxes for the *Extent of the electrical installation covered by this report* and the *Agreed limitations, if any, on the inspection and testing*. Information given here should fully identify the scope of the inspection and testing and of the report. The Approved Contractor should have agreed all such aspects with the person ordering the work and other interested parties (eg insurance company, landlord, mortgagee etc) before the inspection was carried out.

A declaration of the overall condition of the installation should have been given by the inspector in Section F of the report. The declaration must reflect that given in Section H, which summarises the observations and recommendations made in Section G. A list of observations and recommendations for urgent remedial work and corrective action(s) necessary to maintain the installation in a safe working order should have been given in Section G where appropriate. For further guidance on the recommendations, please see the reverse of page 2.

Should the person ordering the periodic inspection (eg the client, as identified on Page 1 of this report) have reason to believe that the report issued by the Approved Contractor does not reasonably reflect the condition of the electrical installation reported on, the person should in the first instance raise the specific concerns in writing with the Approved Contractor. If the concerns remain unresolved, the client may make a formal complaint to NICEIC, for which purpose a standard complaint form is available on request.

The complaints procedure offered by NICEIC is subject to certain terms and conditions, full details of which are available upon application and from the website. NICEIC does not investigate complaints relating to the operational performance of electrical installations (such as lighting levels), or to contractual or commercial issues (such as time or cost).

Irrespective of the method of compilation of the form, all unshaded boxes should have been completed either by insertion of the relevant details or by entering 'N/A', meaning 'Not Applicable', where appropriate.

* NICEIC' is a trading name of NICEIC Group Limited, a wholly owned subsidiary of The Electrical Safety Council. Under licence from The Electrical Safety Council, NICEIC acts as the electrical contracting industry's independent voluntary regulatory body for electrical installation safety matters throughout the UK, and maintains and publishes registers of electrical contractors that it has assessed against particular scheme requirements (including the technical standard of electrical work).

For further information about electrical safety and how the NICEIC can help you, visit **www.niceic.com**

G OBSERVATIONS AND RECOMMENDATIONS FOR ACTIONS TO BE TAKEN

Referring to the attached schedules of inspection and test results, and subject to the limitations at D:

There are no items adversely affecting electrical safety.

or

The following observations and recommendations are made.

Item No		Code †
1		

Note: If necessary, continue on additional page(s), which must be identified by the Domestic Periodic Inspection Report serial number and page number(s).

† Where observations are made, the inspector will have entered one of the following codes against each observation to indicate the action (if any) recommended:-

- 'requires urgent attention' or
- 'requires improvement' or
- 'requires further investigation' or
- 'does not comply with BS 7671: 2001 (as amended)'

Please see the reverse of this page for guidance regarding the recommendations.

Urgent remedial work recommended for Items: Corrective action(s) recommended for Items:

H SUMMARY OF THE INSPECTION

General condition of the installation:

Note: If necessary, continue on additional page(s), which must be identified by the Domestic Periodic Inspection Report serial number and page number(s).

Date(s) of the inspection:

Overall assessment of the installation:
(Entry should read either 'Satisfactory' or 'Unsatisfactory')

I NEXT INSPECTION

I/We recommend that this installation is further inspected and tested after an interval of not more than:

(Enter interval in terms of years or months, as appropriate)

provided that any items at G which have been attributed a Recommendation Code 1 (requires urgent attention) are remedied without delay. Items which have been attributed a Recommendation Code 2 or 3 should be actioned as soon as practicable (see G).

J SUPPLY CHARACTERISTICS, EARTHING AND BONDING ARRANGEMENTS

Enter details, as appropriate

Supply Characteristics	System Type(s)	Characteristics of Primary Supply Overcurrent Protective Device(s)	Main Switch or Circuit-Breaker		Means of Earthing	Main Protective Conductors		
Nominal voltage, $U^{(1)}$ <input type="text"/> V	TN-S <input type="checkbox"/>	BS(EN) <input type="text"/>	Type: <input type="text"/>	Voltage rating <input type="text"/> V	Distributor's facility: <input type="text"/>	Earthing conductor		Main equipotential bonding conductors
Nominal frequency, $f^{(1)}$ <input type="text"/> Hz			No of Poles <input type="text"/>	Current rating, I_n <input type="text"/> A	Installation earth electrode: <input type="text"/>	Conductor material <input type="text"/>	Conductor material <input type="text"/>	
Prospective fault current, $I_{pf}^{(2)}$ <input type="text"/> kA	TN-CS <input type="checkbox"/>	Type <input type="text"/>	Supply conductors material <input type="text"/>	RCD operating current, $I_{\Delta n}^*$ <input type="text"/> mA	Type: <input type="text"/>	Conductor csa <input type="text"/> mm ²	Conductor csa <input type="text"/> mm ²	Conductor csa <input type="text"/> mm ²
External earth fault loop impedance, $Z_e^{(3)}$ <input type="text"/> Ω	TT <input type="checkbox"/>	Nominal current rating <input type="text"/> A	Supply conductors material <input type="text"/>	RCD operating time (at $I_{\Delta n}^*$) <input type="text"/> ms	(eg rod(s), tape etc) <input type="text"/>	Continuity check <input type="checkbox"/> (✓)	Continuity check <input type="checkbox"/> (✓)	Continuity check <input type="checkbox"/> (✓)
Notes: (1) by enquiry (2) by enquiry or by measurement (3) by measurement		Short-circuit capacity <input type="text"/> kA	Supply conductors csa <input type="text"/> mm ²	<i>*(applicable only where an RCD is used as a main circuit-breaker)</i>	Electrode resistance, R_A : <input type="text"/> (Ω)	Bonding of extraneous-conductive-parts (✓)		
					Location: <input type="text"/>	Water service <input type="checkbox"/>	Gas service <input type="checkbox"/>	Lightning protection <input type="checkbox"/>
					Method of measurement: <input type="text"/>	Oil service <input type="checkbox"/>	Structural steel <input type="checkbox"/>	Other incoming service(s) <input type="checkbox"/>

Please see the 'Notes for Recipients' on the reverse of this page.

Only one Recommendation Code should have been given for each recorded observation.

Recommendation Code 1

Where an observation has been given a Recommendation Code 1 (requires urgent attention), the safety of those using the installation may be at risk.

The person responsible for the maintenance of the installation is advised to take action without delay to remedy the observed deficiency in the installation, or to take other appropriate action (such as switching off and isolating the affected part(s) of the installation) to remove the potential danger. The NICEIC Approved Contractor issuing this report will be able to provide further advice.

It is important to note that the recommendation given at Section I *Next Inspection* of this report for the maximum interval until the next inspection is conditional upon all items which have been given a Recommendation Code 1 being remedied without delay (see Section G).

Recommendation Code 2

Recommendation Code 2 (requires improvement) indicates that, whilst the safety of those using the installation may not be at immediate risk, remedial action should be taken as soon as possible to improve the safety of the installation to the level provided by the national standard for the safety of electrical installations, BS 7671. The NICEIC Approved Contractor issuing this report will be able to provide further advice.

Items which have been given a Recommendation Code 2 should be remedied as soon as possible (see Section G).

Recommendation Code 3

Where an observation has been given a Recommendation Code 3 (requires further investigation), the inspection has revealed an apparent deficiency which could not, due to the extent or limitations of this inspection, be fully identified. Items which have been given a Recommendation Code 3 should be investigated as soon as possible (see Section G).

The person responsible for the maintenance of the installation is advised to arrange for the NICEIC Approved Contractor issuing this report (or other competent person) to undertake further examination of the installation to determine the nature and extent of the apparent deficiency.

Recommendation Code 4

Recommendation Code 4 [does not comply with BS 7671: 2001 (as amended)] will have been given to observed non-compliance(s) with the **current** safety standard which do not warrant one of the other Recommendation Codes. It is not intended to imply that the electrical installation inspected is unsafe, but careful consideration should be given to the benefits of improving these aspects of the installation. The NICEIC Approved Contractor issuing this report will be able to provide further advice.

